

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. _____ Date 3-30-76
Installation for SAM HAWKER at Sec 21 T6S R34
(Name) (Legal description of property)

Address of Installation See APPLICATION

No. Living Units 1 Bedrooms 3 People Served 3 Water Supply--Private Public _____ Applicant is: Owner Contractor _____ Other _____

FHA _____ FARM HOME _____ VA _____ CONV. _____ EXISTING _____ NO. _____

Septic Tank 1000 gal. 360 Perc. Rate 5 1/2 Min./in. Min. Depth to Ground Water _____ ft.

Effluent Disposal: Effective Area Required _____ sq. ft. Soil System: Soil Profile _____
Field Drain Absorption Bed _____ Standard Modified _____ Seepage Pit _____ Dimensions _____

Distance from Disposal Area to:
Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 15 ft. Well 100 ft.
Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved Septic Tank 10 ft.

Remarks: Do not backfill without prior inspection

Applicant Samuel S. Hawker Paid _____ Bill _____ No Fee _____

Address _____ Permit Issued by Tom Hopkins

INSPECTION: Septic Tank Size 1000 Standpipe 2' Depth to Manhole 12"

Distance from Septic Tank to: Dwelling Foundation _____ ft. Well _____ ft. Nearest Neighbor's Well _____ ft.

Effluent Disposal: Effective Area 600 sq. ft.
Field Drain Absorption Bed _____ Standard _____ Modified _____ Seepage Pit _____ Dimensions _____

Pipe Size 4" No. of Lines 2 Length 100 Depth 2-3' 20' apart

Distance from Disposal Area to:
Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.
Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.

Approved Not Approved _____ Inspected 14 April 76 W.H. Mathews Installed by Tri City Concrete
(Date)

Remarks _____

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

FIELD DRAIN: EXAMPLE

2 TRENCHES 100'-0 LONG X 3'-0 WIDE. MIN. 6'-0 UNDISTURBED EARTH BETWEEN LINES. ALL LINES INTERCONNECTED.

INSTALL AS PER 