

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

1:30 - 30 Mar

Permit No. _____ Date 22 March 1976
Installation for Mike Scardino at Lot 3 Sed 2 T6S R 34EB-4
(Name) (Legal description of property)

Address of Installation Buffalo Road 1 mile north of E. Chubbuck Rd

No. Living Units 1 Bedrooms 4 People Served 2 Water Supply--Private Public Applicant is: Owner Contractor Other

FHA _____ FARM HOME _____ VA _____ CONV. _____ EXISTING _____ NO. _____

Septic Tank 1000 gal. Perc. Rate 6 1/2 Min./in. Min. Depth to Ground Water _____ ft.

Effluent Disposal: Effective Area Required 600 sq. ft. Soil System: _____ Soil Profile _____
Field Drain _____ Absorption Bed _____ Standard Modified _____ Seepage Pit Dimensions _____

Distance from Disposal Area to:
Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 20 ft. Well 100 ft.

Surface Water _____ ft. Nearest Neighbor's Well _____ ft. Plot Plan Submitted and Approved _____ Septic Tank _____ ft.

Remarks: Have sewer system inspected + approved before backfilling

Applicant X Dick Dewey Paid _____ Bill _____ No Fee _____
Address _____ Permit Issued by William H. Mailman

INSPECTION: Septic Tank Size _____ Standpipe _____ Depth to Manhole _____

Distance from Septic Tank to: Dwelling Foundation _____ ft. Well _____ ft. Nearest Neighbor's Well _____ ft.

Effluent Disposal: Effective Area _____ sq. ft.
Field Drain _____ Absorption Bed _____ Standard _____ Modified _____ Seepage Pit _____ Dimensions _____

Pipe Size _____ No. of Lines _____ Length _____ Depth _____

Distance from Disposal Area to:
Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.

Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.

Approved Not Approved _____ Inspected 30 Mar 76 by W. H. Mailman Installed by John Long
(Date)

Remarks by Phone

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

