

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

DP

Permit No. _____ Date 1-5-76
Installation for STEWART NELSON at NW 1/4 Sec 5 T 05 S 34 E
(Name) (Legal description of property)

Address of Installation SEE APPLICATION
No. Living Units 1 Bedrooms 4 People Served 4 Water Supply--Private Public _____
Applicant is: Owner _____ Contractor Other _____
FHA _____ FARM HOME _____ VA _____ CONV. _____ EXISTING _____ NO. _____

Septic Tank 1000 gal. 400
Effluent Disposal: Effective Area Required 400 sq. ft. Soil System: Perc. Rate 30 Min./in. Min. Depth to Ground Water _____ ft.
Soil Profile _____
Field Drain Absorption Bed _____ Standard _____ Modified _____ Seepage Pit Dimensions _____

Distance from Disposal Area to:
Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 15 ft. Well 100 ft.
Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved Septic Tank 10 ft.

Remarks: DO NOT BACKFILL WITHOUT PRIOR INSPECTION
Applicant Stewart Nelson Paid _____ Bill _____ No Fee
Address _____ Permit Issued by Tom Hopkins

INSPECTION: Septic Tank Size _____ Standpipe _____ Depth to Manhole _____
Distance from Septic Tank to: Dwelling Foundation _____ ft. Well _____ ft. Nearest Neighbor's Well _____ ft.
Effluent Disposal: Effective Area _____ sq. ft.
Field Drain _____ Absorption Bed _____ Standard _____ Modified _____ Seepage Pit _____ Dimensions _____

Pipe Size _____ No. of Lines _____ Length _____ Depth _____
Distance from Disposal Area to: 31" inside dia 10'6" deep 13' dia pit
Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.
Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.
Approved Not Approved _____ Inspected 31 March by Harry Ferguson (Date) Installed by Gary Porter

Remarks _____

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

THIS SYSTEM IS DESIGNED FOR MAXIMUM FIELD DRAIN DUE TO NO PERC TEST, FROZEN GROUND. THE SIZE OF AREA MAY BE CHANGED IF A VALID PERCOLATION TEST IS PERFORMED AND THE RESULTS SUBMITTED TO THIS OFFICE.

Chng 3-26-76 TO SEEPAGE PIT. 400 SQ FT. REQUIRED
SEEPAGE PIT 13'-0 DIA X 10'-0 DEEP BELOW INLET.
LEAVE LID TO SEEPAGE PIT OFF BEFORE INSPECTION