

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Date March 31, 1977

Permit No. \_\_\_\_\_ Installation for Randy Lewis at SE<sup>4</sup> NW<sup>4</sup> Sec 33 T5 S5 R 34 E2M

Address of Installation 1 mi up Grant Crk Turn Left at Meadow back onto Rd

No. Living Units 1 Bedrooms 3 People Served 4 Water Supply--Private  Public \_\_\_\_\_ Applicant is: Owner  Contractor \_\_\_\_\_ Other \_\_\_\_\_

FHA \_\_\_\_\_ FARM HOME \_\_\_\_\_ VA \_\_\_\_\_ CONV.  EXISTING \_\_\_\_\_ NO. \_\_\_\_\_

Septic Tank 1000 gal. Perc. Rate 14 Min. In. Min. Depth to Ground Water N/A ft.

Effluent Disposal: Effective Area Required 570 sq. ft. Soil System: Soil Profile span

Field Drain  Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit \_\_\_\_\_ Dimensions \_\_\_\_\_

Distance from Disposal Area to: Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 20 ft. Well 100 ft.

Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved  Septic Tank 6 ft.

Remarks: \_\_\_\_\_

Applicant Randy Lewis Paid \_\_\_\_\_ Bill \_\_\_\_\_ No Fee

Address \_\_\_\_\_ Permit Issued by Jack Palmer

INSPECTION: Septic Tank Size 1000 Standpipe no Depth to Manhole 17"

Distance from Septic Tank to: Dwelling Foundation 10' ft. Well 100 ft. Nearest Neighbor's Well 100 ft.

Effluent Disposal: Effective Area 875 sq. ft.

Field Drain \_\_\_\_\_ Absorption Bed  Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit \_\_\_\_\_ Dimensions 23 x 36

Pipe Size 4" No. of Lines 4 Length 38 Depth 2'0

Distance from Disposal Area to: Property Lines: Front \_\_\_\_\_ ft. Back \_\_\_\_\_ ft. Side \_\_\_\_\_ ft. Dwelling Foundation \_\_\_\_\_ ft. Well \_\_\_\_\_ ft.

Surface Water \_\_\_\_\_ ft. Water Service Piping \_\_\_\_\_ ft. Depth to Gravel \_\_\_\_\_ ft. Nearest Neighbor's Well \_\_\_\_\_ ft.

Approved  Not Approved \_\_\_\_\_ Inspected 5-23-77 by Tom Hopkins Installed by SELF

Remarks \_\_\_\_\_

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

Change to seepage bed 30' x 20' x 3' deep  
approved TH 5-3-77  
1/2 - 2 1/2" gravel - screened & washed