

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

210

Permit No. _____ Date 11-18-77
Installation for Kenneth L. Anderson at Sec 28 T6S R34
(Name) (Legal description of property)

Address of Installation _____
No. Living Units 1 Bedrooms 2 People Served 2 Water Supply--Private
Public Applicant is: Owner
Contractor
Other
FHA FARM HOME VA CONV. EXISTING NO.

Septic Tank 1000 gal.
Effluent Disposal: Effective Area Required 440 sq. ft. Soil System: Perc. Rate _____ Min./in. Min. Depth to Ground Water _____ ft.
Soil Profile _____
Field Drain Absorption Bed _____ Standard _____ Modified _____ Seepage Pit _____ Dimensions _____

Distance from Disposal Area to:
Property Lines: Front 10 ft. Back 10 ft. Side 16 ft. Dwelling Foundation 20 ft. Well 100 ft.
Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved Septic Tank 10 ft.

Remarks: DO NOT BACKFILL WITHOUT PRIOR NOTIFICATION
Applicant X Sewer Growth Paid _____ Bill _____ No Fee
Address _____ Permit Issued by Tom Hopkins

INSPECTION: Septic Tank Size 1000 Standpipe no Depth to Manhole 12"
Distance from Septic Tank to: Dwelling Foundation 5 ft. Well 150 ft. Nearest Neighbor's Well _____ ft.
Effluent Disposal: Effective Area _____ sq. ft.
Field Drain Absorption Bed _____ Standard Modified _____ Seepage Pit _____ Dimensions 2 lines x 70'-0
Pipe Size 4 No. of Lines 2 Length 70 Depth 2'-3'

Distance from Disposal Area to:
Property Lines: Front L10 ft. Back L10 ft. Side L10 ft. Dwelling Foundation 20 ft. Well 100 ft.
Surface Water 150 ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.
Approved Not Approved _____ Inspected 9/13/78 by Tom Hopkins Installed by RICHARD BROWNING
(Date)
Remarks Held For Certification

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --
NOTE: System must be installed by a licensed SEWER INSTALLER IF NOT installed by Home owner.