

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. \_\_\_\_\_ Date 17 May 1976  
 Installation for C.W. Lamb at Sec 1 T 75 R 34 E 13 M  
(Name) (Legal description of property)  
 Address of Installation So. Grant Cpt.  
 No. Living Units 1 Bedrooms 3 People Served 3 Water Supply--Private  Public \_\_\_\_\_ Applicant is: Owner  Contractor \_\_\_\_\_ Other \_\_\_\_\_  
 FHA \_\_\_\_\_ FARM HOME \_\_\_\_\_ VA \_\_\_\_\_ CONV. \_\_\_\_\_ EXISTING \_\_\_\_\_ NO. \_\_\_\_\_

Septic Tank 1000 gal. Perc. Rate 20 Min./in. Min. Depth to Ground Water \_\_\_\_\_ ft.  
 Effluent Disposal: Effective Area Required 700 sq. ft. Soil System: Soil Profile \_\_\_\_\_  
 Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit  Dimensions 10' deep x 18' on side

Distance from Disposal Area to:  
 Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 20 ft. Well 100 ft. 72ft prim.  
 Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved  Septic Tank 5 ft.

Remarks: Have sewer system inspected and approved before backfilling  
 Applicant C.W. Lamb Paid \_\_\_\_\_ Bill \_\_\_\_\_ No Fee \_\_\_\_\_  
 Address X RT 1 So. Box 166 Permit Issued by William H. Maltraves

INSPECTION: Septic Tank Size 1000 Standpipe \_\_\_\_\_ Depth to Manhole 12"  
 Distance from Septic Tank to: Dwelling Foundation 60 ft. Well 80 ft. Nearest Neighbor's Well \_\_\_\_\_ ft.  
 Effluent Disposal: Effective Area 702 sq. ft.  
 Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit  Dimensions 9' x 20 1/4 x 18 1/2  
 Pipe Size \_\_\_\_\_ No. of Lines \_\_\_\_\_ Length \_\_\_\_\_ Depth \_\_\_\_\_

Distance from Disposal Area to:  
 Property Lines: Front 150 ft. Back 100 ft. Side 10 ft. Dwelling Foundation 60 ft. Well 100 ft.  
 Surface Water 150 ft. Water Service Piping \_\_\_\_\_ ft. Depth to Gravel \_\_\_\_\_ ft. Nearest Neighbor's Well \_\_\_\_\_ ft.  
 Approved \_\_\_\_\_ Not Approved  Inspected 7-19-76 by Fred Hoffman Installed by \_\_\_\_\_  
(Date)

Remarks \_\_\_\_\_

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --  
final approval contingent upon installation of cast iron across the septic tank area of disturbed earth from house to tank and tank to disposal area