

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

210

Permit No. _____ Date May 20, 1977
Installation for Lance Troughter at NE 1/4 Sec 8 T6S R. 94E
(Name) (Legal description of property)

Address of Installation CHUBBUCK ROAD

No. Living Units 1 Bedrooms 4 People Served 6 Water Supply--Private Public _____ Applicant is: Owner Contractor _____ Other _____

FHA _____ FARM HOME _____ VA _____ CONV. _____ EXISTING _____ NO. _____

Septic Tank 1000 gal. Perc. Rate 1 Min./in. Min. Depth to Ground Water _____ ft.

Effluent Disposal: Effective Area Required 300 * sq. ft. Soil System: _____ Soil Profile _____

Field Drain _____ Absorption Bed _____ Standard _____ Modified _____ Seepage Pit Dimensions 10' deep below inlet x 10' diam

Distance from Disposal Area to: _____ *
Property Lines: Front 710 ft. Back 710 ft. Side 710 ft. Dwelling Foundation 25 ft. Well 100 ft.

Surface Water 150 ft. Nearest Neighbor's Well 600 ft. Plot Plan Submitted and Approved Septic Tank 15 ft.

Remarks: Call for inspection before backfilling 233-9080

Applicant Lance Troughter Paid _____ Bill _____ No Fee

Address _____ Permit Issued by Fred Huffman

INSPECTION: Septic Tank Size 1000 Standpipe 4'-0 Depth to Manhole 12-18"

Distance from Septic Tank to: Dwelling Foundation 25 ft. Well 100 ft. Nearest Neighbor's Well _____ ft.

Effluent Disposal: Effective Area 300 sq. ft.

Field Drain _____ Absorption Bed _____ Standard _____ Modified _____ Seepage Pit Dimensions 20'-0 x 10'-0

Pipe Size _____ No. of Lines _____ Length _____ Depth _____

Distance from Disposal Area to: _____

Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.

Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.

Approved Not Approved _____ Inspected 6-27-77 by Tom Hopkins Installed by TARGLER CONST.
(Date)

Remarks approve via phone - GARY DICKSON

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

- * Pit size - 10' deep below inlet x 10' diam.
- * Pit must be at least 100' from the well and 150' from surface water (stream, main canal) ~~and~~
- 6'-

install as per 7