

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

000

Permit No. \_\_\_\_\_ Date 16 Feb. 1977  
Installation for BANNOCK County Fairgrounds at Caretakers Home  
(Name) (Legal description of property)

Address of Installation T65 R34E Sec 12

No. Living Units 1 Bedrooms 3 People Served 5 Water Supply—Private \_\_\_\_\_ Public \_\_\_\_\_  
Applicant is: Owner  Contractor \_\_\_\_\_ Other \_\_\_\_\_  
FHA \_\_\_\_\_ FARM HOME \_\_\_\_\_ VA \_\_\_\_\_ CONV. \_\_\_\_\_ EXISTING \_\_\_\_\_ NO. \_\_\_\_\_

Septic Tank 1000 gal. TANK existing Perc. Rate \_\_\_\_\_ Min./in. Min. Depth to Ground Water \_\_\_\_\_ ft.  
Effluent Disposal: Effective Area Required \_\_\_\_\_ sq. ft. Soil System: Soil Profile \_\_\_\_\_  
Field Drain  Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit \_\_\_\_\_ Dimensions \_\_\_\_\_

Distance from Disposal Area to:  
Property Lines: Front \_\_\_\_\_ ft. Back \_\_\_\_\_ ft. Side \_\_\_\_\_ ft. Dwelling Foundation \_\_\_\_\_ ft. Well \_\_\_\_\_ ft.  
Surface Water \_\_\_\_\_ ft. Nearest Neighbor's Well \_\_\_\_\_ ft. Plot Plan Submitted and Approved \_\_\_\_\_ Septic Tank \_\_\_\_\_ ft.

Remarks: \_\_\_\_\_

Applicant Jim Kluesner Paid \_\_\_\_\_ Bill \_\_\_\_\_ No Fee   
Address Radiata grounds Permit Issued by HARRY FUGROW

INSPECTION: Septic Tank Size 1000 Standpipe 4' Depth to Manhole 12"

Distance from Septic Tank to: Dwelling Foundation \_\_\_\_\_ ft. Well \_\_\_\_\_ ft. Nearest Neighbor's Well \_\_\_\_\_ ft.

Effluent Disposal: Effective Area \_\_\_\_\_ sq. ft.  
Field Drain  Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit \_\_\_\_\_ Dimensions \_\_\_\_\_  
Pipe Size 4 No. of Lines 4 Length 100 Depth 4'-0

Distance from Disposal Area to:  
Property Lines: Front \_\_\_\_\_ ft. Back \_\_\_\_\_ ft. Side \_\_\_\_\_ ft. Dwelling Foundation \_\_\_\_\_ ft. Well \_\_\_\_\_ ft.  
Surface Water \_\_\_\_\_ ft. Water Service Piping \_\_\_\_\_ ft. Depth to Gravel \_\_\_\_\_ ft. Nearest Neighbor's Well \_\_\_\_\_ ft.

Approved  Not Approved \_\_\_\_\_ Inspected 3-14-77 by Tom Hopkins Installed by County  
(Date)

Remarks \_\_\_\_\_

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

Minimum size of system:  
4 Trenches - each 2 1/2' wide and 100' long.  
Suggest corrugated, perforated drain lines.  
Minimum 6" screened, washed gravel 1/2 - 1 1/2" dia  
under pipe -   
lines to be level.  
OR. 4-5 layers news print.  
Trenches to be at least 8' apart center to center.  
ends to be connected.  
otherwise install as per