

WATER AND SEWER PERMIT

Southeastern
District Health Department

PLANNING & ZONING APPROVAL

Name (Russ Gimlin) J. R. SIMPLOT CO.	Phone 232-6620	Property Address ly
Address P.O. Box 912 Pocatello		Legal Description T. 6 S. R. 34 Sec 7
Report To	Funding <input type="checkbox"/> Governmental <input type="checkbox"/> Individual	<input type="checkbox"/> Conventional <input type="checkbox"/> Existing Loan No.

SEWAGE SYSTEM

Installation shall comply with all requirements of Health District and/or State of Idaho sewage disposal rules, regulations and standards

Permit No.
2829

SIZE	No. Bedrooms	Septic Tank 1000 gal.	Disposal Area 460 sq. ft.	TYPE <input type="checkbox"/> Trench <input type="checkbox"/> Bed	<input checked="" type="checkbox"/> Pit <input type="checkbox"/> E.T.	<input type="checkbox"/> Sand Filter <input type="checkbox"/> Modified	Permit Fee 50⁰⁰
Dimensions 11x15x9'-0"	Maximum Depth below Ground Surface		PLOT PLAN	<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved		By Tom Hopkins	Date 7-16-84
Remarks				Applicant's Signature X Thomas J. Liddie		Permit Fee pd 50⁰⁰ 9321	

INSPECTION

The District Health Department shall be notified of installation **48** prior to ^{**Backfill**} installation

SEPTIC TANK SIZE 1000 gal.	STANDPIPE <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Manhole Depth 12"	DEPTH OF Ground Water	Bedrock	Gravel	Rock Under Pipe
Minimum Distances as per Regulations <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Approved Aggregate <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Effective Disposal Area 500 sq. ft.		Installer Tom Liddie
EXISTING SYSTEM Appears to meet Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No		INSTALLATION <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved		By X Tom Hopkins		Date 8-7-84
Remarks						Permit Fee

WATER SYSTEM

Plans Approved <input type="checkbox"/> Yes <input type="checkbox"/> No	State Laboratory indicates intestinal bacteria <input type="checkbox"/> were <input type="checkbox"/> were not found in water.	Sample Collected By	Date	Permit Fee
Min. Distances as per Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No		CHEMICAL TOLERANCES Acceptable Limits <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Chk'd		System <input type="checkbox"/> Public <input type="checkbox"/> Private
Existing System appears to comply with all requirements of Health Dist. and State of Idaho Drinking Water Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No			INSTALLATION <input type="checkbox"/> Approved <input type="checkbox"/> Disapproved	
By X				Date
Remarks				Permit Fee

DIAGRAM

Where applicable, diagram shall include orientation of components of water and sewage systems

PERMIT TO INSTALL A SEPTIC TANK AND SEEPAGE FOR 12 EMPLOYEES
There will be 1 HAND BASIN AND 1 URINAL AND 2 WATER CLOSETS.

to 14 x 14 x 10'-0"

Seepage Pit - 11 x 14 x 10'-0" SQUARE.

NOTE - 3" DRAIN REQUIRED OVER SEPTIC TANK TO PREVENT WATER FROM INFILTRATING THE SEPTIC TANK