

Mountain States Builders inspect 3:00

Robert De Long

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Re

Permit No. \_\_\_\_\_ Date 2-13-76

Installation for Jim Voelke & Bill Esley at Lot C Sec 4 T 75 R 34  
(Name) (Legal description of property)

Address of Installation See Application

No. Living Units 1 Bedrooms 3 People Served 4 Water Supply--Private  Public  Applicant is: Owner  Contractor  Other

FHA \_\_\_\_\_ FARM HOME \_\_\_\_\_ VA \_\_\_\_\_ CONV. \_\_\_\_\_ EXISTING \_\_\_\_\_ NO. \_\_\_\_\_

Septic Tank ~~1500~~ gal 1000 800 Perc. Rate 40 Min./in. Min. Depth to Ground Water \_\_\_\_\_ ft.

Effluent Disposal: Effective Area Required 400 sq. ft. Soil System: \_\_\_\_\_ Soil Profile \_\_\_\_\_

Field Drain  Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit \_\_\_\_\_ Dimensions \_\_\_\_\_

Distance from Disposal Area to:

Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 20 ft. Well 100 ft.  
Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved  Septic Tank 10 ft.

Remarks: DO NOT BACKSILL WITHOUT PRIOR INSPECTION

Applicant Jim Voelke Paid \_\_\_\_\_ Bill \_\_\_\_\_ No Fee

Address \_\_\_\_\_ Permit Issued by Tom Hopkins

INSPECTION: Septic Tank Size 1000 Standpipe \_\_\_\_\_ Depth to Manhole \_\_\_\_\_

Distance from Septic Tank to: Dwelling Foundation 10 ft. Well \_\_\_\_\_ ft. Nearest Neighbor's Well \_\_\_\_\_ ft.

Effluent Disposal: Effective Area 1200 sq. ft.

Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit  Dimensions 12' deep x 24x35'

Pipe Size \_\_\_\_\_ No. of Lines \_\_\_\_\_ Length \_\_\_\_\_ Depth \_\_\_\_\_

Distance from Disposal Area to:

Property Lines: Front 7/10 ft. Back 7/10 ft. Side 7/10 ft. Dwelling Foundation 35 ft. Well \_\_\_\_\_ ft.  
Surface Water \_\_\_\_\_ ft. Water Service Piping 250 ft. Depth to Gravel 2 ft. Nearest Neighbor's Well \_\_\_\_\_ ft.

Approved  Not Approved \_\_\_\_\_ Inspected 12-1-76 by Fred Heffner Installed by Richard Browning  
(Date)

Remarks \_\_\_\_\_

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

3- 100'-0 Lines x 3'-0 Wide. Minimum 6'-0 Between lines undisturbed  
EARTH Between Lines. ALL Lines to be interconnected.  
- May put in Pit - Tom H. OKed - Told him  
(Browning) Tom wants to inspect it when  
done  
120'