

WATER AND SEWER PERMIT

Southeastern District Health Department

PLANNING & ZONING APPROVAL

Name <i>Hunziker Construction Co.</i>	Phone <i>237-1043</i>	Property Address <i>Rio Vista Road, 3/8 mile North of Chubbuck Rd.</i>
Address <i>P.O. Box 4836, Pocatello, Idaho 83205</i>	Legal Description <i>SE 1/4, Sec. 6, T. 6 S. R. 34 E., R. 1 M.</i>	
Report To	Funding <input checked="" type="checkbox"/> Individual	<input type="checkbox"/> Governmental <input type="checkbox"/> Conventional <input type="checkbox"/> Existing

SEWAGE SYSTEM

Installation shall comply with all requirements of Health District and/or State of Idaho sewage disposal rules, regulations and standards

No. Bedrooms	Septic Tank <i>1000 gal.</i>	Disposal Area <i>667 sq. ft.</i>	TYPE <input checked="" type="checkbox"/> Trench <input type="checkbox"/> Bed	<input type="checkbox"/> Pit <input type="checkbox"/> E.T.	<input type="checkbox"/> Sand Filter <input type="checkbox"/> Modified	Permit No. <i>3988</i>
SIZE <i>OFFICE/SHOP</i>	Maximum Depth below Ground Surface <i>4'</i>	PLOT PLAN	<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved	By <i>A. Hancock</i>	Date <i>10/29/87</i>	Permit Fee <i>\$50.00</i>
Remarks	Applicant's Signature <i>X Albert Johnson</i>				Permit Fee <i>\$50.00</i>	

INSPECTION

The District Health Department shall be notified of installation *48 hrs* prior to ^{back fill} installation

SEPTIC TANK <i>1000 gal.</i>	Size <i>1000 gal.</i>	STANDPIPE <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Manhole Depth	DEPTH OF Ground Water	Bedrock	Gravel	Rock Under Pipe <i>12"</i>
Minimum Distances as per Regulations <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Approved Aggregate <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Effective Disposal Area <i>700 sq. ft.</i>	Installer <i>Lee Marcham</i>				
EXISTING SYSTEM Appears to meet Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	INSTALLATION <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved	By <i>X Margaret M. Simon</i>	Date <i>3-10-88</i> <i>3-11-88</i>				

Remarks
Disposal area only 525, top of tank already covered. need 142 sq ft more trench. OK, connected 3-11-88

WATER SYSTEM

Plans Approved <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	State Laboratory indicates intestinal bacteria <input type="checkbox"/> were <input type="checkbox"/> were not found in water.	Sample Collected By	Date <i>10/29/87</i>	Permit Fee <i>-</i>
Min. Distances as per Standards/Regs <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CHEMICAL TOLERANCES Acceptable Limits <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Chk'd	System <input type="checkbox"/> Public <input checked="" type="checkbox"/> Private	Complies with Health Dist. and/or State of Idaho Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	
Existing System appears to comply with all requirements of Health Dist. and State of Idaho Drinking Water Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	INSTALLATION <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved	By <i>X Margaret M. Simon</i>	Date <i>3-11-88</i>	

Remarks
Sanitary seal not in place yet, temporary covers on well casing

DIAGRAM

Where applicable, diagram shall include orientation of components of water and sewage systems

10-29-87 = Tom OK'd

APPLICATION & PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE South

This system to be designed at 300 gpd.

TRAVEL TIME *15* test hole

INSPEC. TIME *25* test hole

travel time 45

insp time 60 (2 visits)

