

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

20

Permit No. _____ Date 9/7/76
Installation for LARRY RATLIFF at Sec 30 T 25 R 39 E
(Name) (Legal description of property)

Address of Installation SEE APPLICATION - Mink Cr. Rd. - Elk Rd.

No. Living Units 1 Bedrooms 3 People Served 4 Water Supply--Private Public Applicant is: Owner Contractor Other

FHA _____ FARM HOME _____ VA _____ CONV. _____ EXISTING _____ NO. _____

Septic Tank 1000 gal. Perc. Rate _____ Min./in. Min. Depth to Ground Water _____ ft.

Effluent Disposal: Effective Area Required 475 sq. ft. Soil System: _____ Soil Profile _____
Field Drain Absorption Bed _____ Standard Modified _____ Seepage Pit _____ Dimensions _____

Distance from Disposal Area to:
Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 25 ft. Well 100 ft.
Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved _____ Septic Tank 10 ft.

Remarks: DO NOT BACKSILL WITHOUT INSPECTION

Applicant Larry Ratliff Paid _____ Bill _____ No Fee
Address _____ Permit Issued by Tom Hopkins

INSPECTION: Septic Tank Size 1000 Standpipe 0 Depth to Manhole 12"

Distance from Septic Tank to: Dwelling Foundation 25 ft. Well _____ ft. Nearest Neighbor's Well _____ ft.

Effluent Disposal: Effective Area 510 sq. ft.
Field Drain Absorption Bed _____ Standard _____ Modified _____ Seepage Pit _____ Dimensions 2 lines x 85'-0
Pipe Size 4" No. of Lines 2 Length 85 Depth 12'-3'-0

Distance from Disposal Area to:
Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.
Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.

Approved Not Approved _____ Inspected 9-21-77 by TH - via phone Installed by Browning
(Date)

Remarks See attached Certification

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

EXAMPLE

2 Trenches 80'-0 Long x 3'-0 wide.