

JURISDICTION
0300
TRAVEL TIME: 45
INSPECTION TIME: 45

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
465 MEMORIAL DRIVE
POCATELLO, ID

G.W. G.W.
FEE PD Y N
PERMIT # 666

****APPLICATION AND PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE**

NAME Duane W. Hall		PHONE 234-0522	PROPERTY ADDRESS M-STANG Lane Pocatello, ID		
MAILING ADDRESS: 8198 W. Pharoah		LEGAL DESCRIPTION: LOT SIZE (ACRES) 10			
STREET/P.O. BOX		1/4 SECTION NE SECTION 8 TOWNSHIP 6 RANGE 34E01			
CITY Pocatello		LOT # _____ BLOCK # _____ SUBDIVISION _____			
STATE ID		PARCEL # R 3853014609 FROM TAX ASSESSOR'S OFFICE			
SEPTIC TANK SIZE 1000 gal.	EST TYPE 232	EFFECTIVE DISPOSAL AREA 833 SQ.FT.	SOIL TYPE C-1	MAXIMUM DEPTH BELOW GROUND SURFACE 4'	# BEDROOMS 3

INSTALLATION MUST BE BY LICENSED SEWER INSTALLER OR HOME/LANDOWNER

EHS SIGNATURE Edward G. M...	EHS # 38	APPLICANT SIGNATURE [Signature]	DATE 6/17/93
REMARKS W/DT Basement, will have to install pump system. DRAINFIELD			

THE DISTRICT HEALTH DEPARTMENT SHALL BE NOTIFIED OF INSTALLATION 48 HOURS PRIOR TO **BACKFILLING** INSTALLATION

SEPTIC TANK SIZE 1000 gal	STANDPIPE: () YES (X) NO	MANHOLE DEPTH 10"	DEPTH BELOW GROUND SURFACE 3.5'	ROCK UNDER PIPE 6"
EFFECTIVE DISPOSAL AREA 864 sq. ft.	INSTALLATION APPROVED <input checked="" type="checkbox"/> DISAPPROVED _____	INSTALLER Fresure Const.		INSTALLER # 891
EHS SIGNATURE Steve J. Qu...	DATE 7-21-93	EHS # 64		
REMARKS				

WATER SYSTEM

PLANS APPROVED YES <input checked="" type="checkbox"/> NO _____	SAMPLE COLLECTED BY	DATE 6/17/93	STATE LAB INDICATES INTESTINAL BACTERIA WERE _____ WERE NOT _____ FOUND
MIN. DISTANCES PER STANDARDS/REGS. YES <input checked="" type="checkbox"/> NO _____	CHEMICAL PARAMETERS TESTED WITHIN LIMITS YES _____ NO _____		SYSTEM PUBLIC _____ PRIVATE <input checked="" type="checkbox"/>
WELL (SPRING) APPEARS TO MEET CONSTRUCTION STANDARDS AT TIME OF INSPECTION () YES () NO	EHS SIGNATURE Edward G. M...		EHS # 38
REMARKS NOT COMPLETED AT TIME OF VISIT			

APPROVED PLANS

AS BUILT PLANS

