

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

110

Permit No. _____ Date April 7, 1977
Installation for Earl Pickett + Jim Herzog at NW 1/4 Sec 12 T4 R 24 E 84
(Name) (Legal description of property)

Address of Installation SW Corner of Burnside Highway + Tobacco Creek Rd

No. Living Units _____ Bedrooms 3 People Served _____ Water Supply--Private _____
Public Applicant is: Owner _____ Contractor Other

FHA _____ FARM HOME _____ VA _____ CONV. EXISTING _____ NO. _____

Septic Tank 1000 gal. Perc. Rate 45 Min./in. Min. Depth to Ground Water _____ ft.

Effluent Disposal: Effective Area Required 312 sq. ft. Soil System: _____
Soil Profile _____
Field Drain Absorption Bed _____ Standard Modified _____ Seepage Pit _____ Dimensions 3' wide

Distance from Disposal Area to:
Property Lines: Front 5 ft. Back 5 ft. Side 5 ft. Dwelling Foundation 20 ft. Well 100 ft.
Surface Water N/A ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved Septic Tank 6 ft.

Remarks: _____
Applicant Mary Wallace Paid _____ Bill _____ No Fee _____

Address 836 E. CENTER POCAHELLO Permit Issued by Jack Pickett

INSPECTION: Septic Tank Size 1000 Standpipe 4 1/2 Depth to Manhole 12"

Distance from Septic Tank to: Dwelling Foundation 5 ft. Well _____ ft. Nearest Neighbor's Well _____ ft.

Effluent Disposal: Effective Area 442 sq. ft.
Field Drain Absorption Bed Standard _____ Modified Seepage Pit _____ Dimensions 1 line - 3' - 37' about bed - 14x24

Pipe Size 4 No. of Lines 1 Length 37 Depth 3'
Distance from Disposal Area to: 3 24 3'

Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation 20 ft. Well _____ ft.
Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.

Approved Not Approved _____ Inspected 5-11-77 by Tom Hupke Installed by Burnside
(Date)

Remarks _____

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

