

GW 164

Southeastern District Health Department

Jurisdiction 300

Fee Paid X Y N  
Amount Paid \$3500  
Receipt # 44121  
Permit # 171917  
Renewal Date

EHS # 58 / 58  
Date 7/13/07  
Travel Time 30 / 30  
Inspection Time 30 / 45  
EHS #  
Date  
Activity Code  
Office Time

APPLICATION & PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE Exp. Date July 9, 2008

Name Jimmy + Linda Blaylock Phone 238-9621 Property Address 11595 N. Rio Vista Rd. Pocatello, Idaho  
Mailing Address 11595 N. Rio Vista Rd. Legal Description: Lot Size (Acres) 5  
City Pocatello 1/4 Section - Section 6 Township 6 South Range 34 East  
State Idaho Zip 83202 Lot # - Block # - Subdivision -

Septic Tank Size Existing 1000 gal. Est. Type 233 Effective Disposal Area 556 Sq. Ft. Soil Type B-2 Maximum Depth Below Ground Surface 4' # Bedrooms 3

INSTALLATION MUST BE BY LICENSED SEWER INSTALLER OR HOME/LANDOWNER  
Date July 9, 2007 EHS Signature Ken Keller EHS # 58 Applicant Signature  
Remarks Drain field must be minimum 100' from any well. Wastewater must be equally distributed to each lateral. Trench bottom must be level and in native soil.

INSPECTION: THE DISTRICT HEALTH DEPARTMENT SHALL BE NOTIFIED OF INSTALLATION 48 HOURS PRIOR TO BACKFILLING

Septic Tank Size 1000 gal. Existing Standpipe Y N X Manhole Depth 1 Depth Below Ground Surface 4' Rock Under Pipe NA No. & Type 30 Quilley of Dome Infiltrators  
Effective Disposal Area 556 sq. ft. Code G INSTALLATION APPROVED X DISAPPROVED Installer Jimmy Blaylock Owner  
EHS Signature Ken Keller Date July 13, 2007 EHS # 58  
Remarks Do not drive or park on drain field. Recommend your septic tank be pumped at least every 3 years.

WATER SYSTEM

Min. Distances Per Regs. From Septic System Y X N Water System Public Private X

