

PLANNING & ZONING APPROVAL

# WATER AND SEWER PERMIT

160  
Southeastern  
District Health Department

Name <b>J. R. SIMPLOT COMPANY</b>	Phone <b>232-6620</b>	Property Address <b>P.O. Box 912</b>
Address <b>P.O. Box 912 WEST OF CITY 83201</b>	Legal Description <b>PLANT SITE T6 R34 S?</b>	
Report To	Funding <input checked="" type="checkbox"/> Individual	<input type="checkbox"/> Governmental <input type="checkbox"/> Conventional <input type="checkbox"/> Existing
		Loan No. <b>NONE</b>

### SEWAGE SYSTEM

Installation shall comply with all requirements of Health District and/or State of Idaho sewage disposal rules, regulations and standards

Permit No.

Max. No. Bedrooms <b>1</b>	Septic Tank SIZE <b>SHOP BLDG 600</b>	Capacity <b>1250</b> gal.	Disposal Area <b>255</b> sq. ft.	TYPE <input type="checkbox"/> Trench <input type="checkbox"/> Bed	<input checked="" type="checkbox"/> Pit <input type="checkbox"/> E.T.	<input type="checkbox"/> Sand Filter <input type="checkbox"/> Modified	Permit Fee
Dimensions <b>12'-0" SQ Min.</b>	Maximum Depth below Ground Surface <b>12'-0"</b>	PLOT PLAN	<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved	By <b>W. E. Bennett</b>		Date <b>7/17/81</b>	Permit Fee
Remarks <b>3'-0" BELOW YARD LEVEL SAND &amp; HEAVY COARSE GRAVEL</b>				Applicant's Signature <b>Thomas Liddell</b>			

### INSPECTION

The District Health Department shall be notified of installation \_\_\_\_\_ prior to installation

SEPTIC TANK Size <b>1250</b> gal.	STANDPIPE <input type="checkbox"/> Yes <input type="checkbox"/> No	Manhole Depth	DEPTH OF Ground Water	Bedrock	Gravel	Rock Under Pipe
Minimum Distances as per Regulations <input type="checkbox"/> Yes <input type="checkbox"/> No	Approved Aggregate <input type="checkbox"/> Yes <input type="checkbox"/> No	Effective Disposal Area <b>520</b> sq. ft.	Installer <b>Tom LIDDILL</b>			
EXISTING SYSTEM Appears to meet Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	INSTALLATION <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved	By <b>Fred Huffman</b>	Date <b>7/20/81</b>			
Remarks <b>PIT 15' diam. x 8' 1/2' below inlet Hold for certification FH 7/20/81</b> <b>cert. received 7/20/81 see attached FH</b>						

### WATER SYSTEM

Permit No.

Plans Approved <input type="checkbox"/> Yes <input type="checkbox"/> No	State Laboratory indicates intestinal bacteria <input type="checkbox"/> were <input type="checkbox"/> were not found in water.	Sample Collected By	Date	Permit Fee
Min. Distances as per Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	CHEMICAL TOLERANCES <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Chk'd	System <input type="checkbox"/> Public <input type="checkbox"/> Private	Complies with Health Dist. and/or State of Idaho Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	
Existing System appears to comply with all requirements of Health Dist. and State of Idaho Drinking Water Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	INSTALLATION <input type="checkbox"/> Approved <input type="checkbox"/> Disapproved	By <b>X</b>	Date	Permit Fee
Remarks				

### DIAGRAM

Where applicable, diagram shall include orientation of components of water and sewage systems

\* - Permit issued for 30 min/inch.  
Tom Liddell is to phone in perc. rate.  
\*\* They will go with their own design of a pit 12x12' x 8' below inlet or 389 ft<sup>2</sup>