

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. _____ Date Aug 18, 76
 Installation for ARLO ANDERSON at 5 1/2 of SW 1/4 Sec 17 T6S R35E
 (Name) (Legal description of property)
 Address of Installation Poc CREEK ROAD
 No. Living Units 1 Bedrooms 3 People Served 3 Water Supply--Private Public _____ Applicant is: Owner _____ Contractor Other _____
 FHA _____ FARM HOME _____ VA _____ CONV. _____ EXISTING _____ NO. _____
 Septic Tank 1000 gal. Perc. Rate 5 Min./in. Min. Depth to Ground Water _____ ft.
 Effluent Disposal: Effective Area Required 475 sq. ft. Soil System: _____ Soil Profile _____
 Field Drain _____ Absorption Bed Standard _____ Modified _____ Seepage Pit _____ Dimensions 25' x 20'

Distance from Disposal Area to:
 Property Lines: Front 60 ft. Back 200 ft. Side 60 ft. Dwelling Foundation 20 ft. Well 100 ft.
 Surface Water NA ft. Nearest Neighbor's Well _____ ft. Plot Plan Submitted and Approved Septic Tank 5 ft.
 Remarks: Have system inspected before backfill - submit water sample from well
 Applicant Mr. Arlo Anderson Paid _____ Bill _____ No Fee
 Address Mc. Cammer Idaho Permit Issued by Fred Huffman

INSPECTION: Septic Tank Size 1000 Standpipe _____ Depth to Manhole 18"
 Distance from Septic Tank to: Dwelling Foundation 25 ft. Well >100 ft. Nearest Neighbor's Well 100 ft.
 Effluent Disposal: Effective Area 648 sq. ft.
 Field Drain _____ Absorption Bed Standard _____ Modified _____ Seepage Pit Dimensions 27x24
 Pipe Size _____ No. of Lines 4 Length _____ Depth _____

Distance from Disposal Area to: 270
 Property Lines: Front 270 ft. Back 710 ft. Side 710 ft. Dwelling Foundation 45 ft. Well 250 ft.
 Surface Water _____ ft. Water Service Piping 10 ft. Depth to Gravel 2 ft. Nearest Neighbor's Well 2500 ft.
 Approved Not Approved _____ Inspected Aug 25 76 by Fred Huffman Installed by Clayton Berger
 Remarks _____

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

2
 27x24
 24
 108
 54
 648