

JURISDICTION 300

69 032597

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
465 MEMORIAL DRIVE  
POCATELLO, ID

69, 69 Rec # 43996

FEE PD X Y N  
PERMIT # 113906

TRAVEL TIME: 15  
INSPECTION TIME: 30

Code G

\*\*APPLICATION AND PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE

NAME J. Brador Karen Hamilton		PHONE W-233-7638 232-1969 H	PROPERTY ADDRESS Treyis Ridge, Pocatello ID		
MAILING ADDRESS: P.O. Box 4258		LEGAL DESCRIPTION: LOT SIZE (ACRES) 2 1/2			
STREET/P.O. BOX		1/4 SECTION SW SECTION 17 TOWNSHIP 6S RANGE 35E			
CITY Pocatello		LOT # _____ BLOCK # _____ SUBDIVISION _____			
STATE Idaho		PARCEL # R 3851 00 6708 FROM TAX ASSESSOR'S OFFICE			
SEPTIC TANK SIZE 1250 gal.	EST TYPE 232	EFFECTIVE DISPOSAL AREA 778 SQ.FT.	SOIL TYPE B2	MAXIMUM DEPTH BELOW GROUND SURFACE 3'	# BEDROOMS 5

INSTALLATION MUST BE BY LICENSED SEWER INSTALLER OR HOME/LANDOWNER

EHS SIGNATURE Angela T. Marshall	EHS # 72	APPLICANT SIGNATURE <i>[Signature]</i>	DATE 9-23-96
-------------------------------------	-------------	---	-----------------

REMARKS Excavation + installation by homeowner or licensed installer.

INSPECTION

THE DISTRICT HEALTH DEPARTMENT SHALL BE NOTIFIED OF INSTALLATION 48 HOURS PRIOR TO INSTALLATION

SEPTIC TANK SIZE 1500 gal pre-cast	STANDPIPE: ( ) YES (X) NO	MANHOLE DEPTH 13' 1/4	DEPTH BELOW GROUND SURFACE 2	ROCK UNDER PIPE Infil
EFFECTIVE DISPOSAL AREA 778 sq. ft.	INSTALLATION APPROVED X	DATE 03 25 97	INSTALLER Self	INSTALLER #

EHS SIGNATURE <i>[Signature]</i>	DATE 03 25 97	EHS # 69
-------------------------------------	------------------	-------------

REMARKS Drainfield placement has change due to bedrock (shale). There was only 3ft of earth between laterals (must have 6ft).

WATER SYSTEM

PLANS APPROVED YES X NO	SAMPLE COLLECTED BY	DATE	STATE LAB INDICATES INTESTINAL BACTERIA WERE _____ WERE NOT _____ FOUND
MIN. DISTANCES PER STANDARDS/REGS. YES X NO	CHEMICAL PARAMETERS TESTED WITHIN LIMITS YES _____ NO _____	SYSTEM PUBLIC X PRIVATE	City water

WELL (SPRING) APPEARS TO MEET CONSTRUCTION STANDARDS AT TIME OF INSPECTION ( ) YES ( ) NO	EHS SIGNATURE	EHS #
--	---------------	-------

REMARKS OK to bury from house to Tank and then 48 ft of exit line. Neighbor's well is 40ft in front of house

APPROVED PLANS

AS BUILT PLANS

