

G.W.G.W.

JURISDICTION
300

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
465 MEMORIAL DRIVE
POCATELLO, ID

FEE PD Y N
PERMIT # 56615

TRAVEL TIME: 30
INSPECTION TIME: 45

****APPLICATION AND PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE**

NAME Stephen Klassen		PHONE 232-3995	PROPERTY ADDRESS 9120 W. Pocatello Cr Rd	
MAILING ADDRESS:		LEGAL DESCRIPTION: LOT SIZE (ACRES) 2		
STREET/P.O. BOX 9120 W. Pocatello Cr Rd.		1/4 SECTION N6	SECTION 19	TOWNSHIP 6S
CITY Pocatello		RANGE 35E8M		
STATE ID	ZIP	LOT #	BLOCK #	SUBDIVISION
SEPTIC TANK SIZE 1000 gal. existing		EST TYPE 233	EFFECTIVE DISPOSAL AREA 667 SQ.FT.	SOIL TYPE B2
		MAXIMUM DEPTH BELOW GROUND SURFACE Replacement		# BEDROOMS 4

INSTALLATION MUST BE BY LICENSED SEWER INSTALLER OR HOME/LANDOWNER

EHS SIGNATURE <i>Steve J. Row</i>	EHS # 64	APPLICANT SIGNATURE <i>Stephen R. Klassen</i>	DATE 3-4-99
--------------------------------------	-------------	--	----------------

REMARKS w/infiltrator need 400ft² of drainfield

INSPECTION

THE DISTRICT HEALTH DEPARTMENT SHALL BE NOTIFIED OF INSTALLATION 48 HOURS PRIOR TO INSTALLATION

SEPTIC TANK SIZE 1000 gal. existing	STANDPIPE: (X) YES () NO	MANHOLE DEPTH 24"	DEPTH BELOW GROUND SURFACE 6'	ROCK UNDER PIPE NA
EFFECTIVE DISPOSAL AREA 412.5 sq. ft.	INSTALLATION APPROVED (X) DISAPPROVED ()	INSTALLER SELF		INSTALLER #

EHS SIGNATURE <i>Steve J. Row</i>	DATE 3-9-94	EHS # 64
--------------------------------------	----------------	-------------

REMARKS REPLACEMENT SYSTEM - Infiltrator = 687.5 equivalent ft²

WATER SYSTEM

PLANS APPROVED YES () NO ()	SAMPLE COLLECTED BY	DATE	STATE LAB INDICATES INTESTINAL BACTERIA WERE () WERE NOT () FOUND
MIN. DISTANCES PER STANDARDS/REGS. YES (X) NO ()	CHEMICAL PARAMETERS TESTED WITHIN LIMITS YES () NO ()	SYSTEM PUBLIC () PRIVATE (X)	

WELL (SPRING) APPEARS TO MEET CONSTRUCTION STANDARDS AT TIME OF INSPECTION (X) YES () NO	EHS SIGNATURE <i>Steve J. Row</i>	EHS # 64
--	--------------------------------------	-------------

REMARKS

APPROVED PLANS

AS BUILT PLANS

