

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. T 8073B Date 6/18/73
 Installation for Robert William Surman at Tr N 1/2 NE 1/4 S3 T735 EBM
 (Name) (Legal description of property)
 Address of Installation MINK CREEK ROAD
 No. Living Units 1 Bedrooms 3 People Served 9 Water Supply--Private Public Applicant is: Contractor Other Owner
 FHA FARM HOME VA CONV. EXISTING NO. PROFIT SHARING PLAN (WHERE WORKS)
 Septic Tank 1000 gal. Effluent Disposal: Effective Area Required 700 sq. ft. Soil System: Perc. Rate Min/in. Min. Depth to Ground Water ft.
 Soil Profile clay - some rocks
 Field Drain Absorption Bed Standard Modified Seepage Pit Dimensions 3 lines - 100' long
2 1/2' wide

Distance from Disposal Area to:
 Property Lines: Front 202.49 ft. Back 200.02 ft. Side 432.74 ft. Dwelling Foundation 554.10 ft. Well 100 ft.
 Surface Water ft. Nearest Neighbor's Well 200 ft. Plot Plan Submitted and Approved Septic Tank 16 ft.

Remarks:
 Applicant x Martha S. Surman Paid Mill No Fee
 Address _____ Permit Issued by Jaren Tolman

INSPECTION: Septic Tank Size 1000 gal Standpipe _____ Depth to Manhole 18"
 Distance from Septic Tank to: Dwelling Foundation _____ ft. Well 50" ft. Nearest Neighbor's Well _____ ft.
 Effluent Disposal: Effective Area 810 sq. ft.
 Field Drain Absorption Bed _____ Standard Modified Seepage Pit _____ Dimensions 3' wide
 Pipe Size 4" No. of Lines 3 Length 90' Depth 24"

Distance from Disposal Area to:
 Property Lines: Front ft. Back ft. Side ft. Dwelling Foundation 30' ft. Well 106' ft.
 Surface Water N/A ft. Water Service Piping 10' ft. Depth to Gravel N/A ft. Nearest Neighbor's Well 180' ft.
 Approved Not Approved _____ Inspected 7-6-73 by Jaren Tolman Installed by R. Browning
 (Date)

Remarks _____

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components)

