

3027 90.00 \$150.
 4736 60.00 \$150.
 FEE PD Y N
 PERMIT # 164485

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
 1901 ALVIN RICKEN DRIVE POCATELLO, ID 83201

08/20/04

Gal GW

SECTION 300
 SCHEDULE TIME: 45 / /
 INSPECTION TIME: 45 / /

****APPLICATION AND PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE**

NAME Tucker Dahlke		PHONE 254-9166	PROPERTY ADDRESS North Bonnevile Road		
MAILING ADDRESS PO BOX 197		LEGAL DESCRIPTION: LOT SIZE (ACRES) 17.2			
STREET/P.O. BOX		1/4 SECTION 26 SECTION 24 TOWNSHIP 7 RANGE 36			
CITY McCammon		LOT # _____ BLOCK # _____ SUBDIVISION _____		PARCEL # R4015018602 FROM TAX ASSESSOR'S OFFICE	
STATE Idaho		ZIP 83250			
SEPTIC TANK SIZE 1250 gal.	EST TYPE 232	EFFECTIVE DISPOSAL AREA 778 SQ. FT.	SOIL TYPE B2	MAXIMUM DEPTH BELOW GROUND SURFACE 4ft	# BEDROOMS 5

INSTALLATION MUST BE BY LICENSED SEWER INSTALLER OR HOME/LANDOWNER

DATE 02/27/04	EHS SIGNATURE <i>[Signature]</i>	EHS# 69	APPLICANT SIGNATURE <i>[Signature]</i>
REMARKS This copy of Permit was made because I got off scale drawing on '95 built plans' - GF			
THE DISTRICT HEALTH DEPARTMENT SHALL BE NOTIFIED OF INSTALLATION 48 HOURS PRIOR TO BACKFILLING			
SEPTIC TANK SIZE 1250 gal.	STANDPIPE: () YES (X) NO	MANHOLE DEPTH 14 inches	DEPTH BELOW GROUND SURFACE 4ft 2 1/2
EFFECTIVE DISPOSAL AREA 778 sq. ft.	INSTALLATION APPROVED <input checked="" type="checkbox"/> DISAPPROVED _____	INSTALLER Jeff Harris	INSTALLER # 900
EHS SIGNATURE <i>[Signature]</i>	DATE 08/20/04	CODE G	EHS # 69
REMARKS Pump Tank Every 3 years.			

WATER SYSTEM			
PLANS APPROVED YES <input checked="" type="checkbox"/> NO _____	SAMPLE COLLECTED BY	DATE	STATE LAB INDICATES INTESTINAL BACTERIA WERE _____ WERE NOT _____ FOUND
MIN. DISTANCES PER STANDARDS/REGS. YES _____ NO _____	CHEMICAL PARAMETERS TESTED WITHIN LIMITS YES _____ NO _____		SYSTEM PUBLIC _____ PRIVATE <input checked="" type="checkbox"/>
WELL (SPRING) APPEARS TO MEET CONSTRUCTION STANDARDS AT TIME OF INSPECTION () YES () NO Not installed	EHS SIGNATURE NA		EHS# NA
REMARKS Plan to go on North side of House			

APPROVED PLANS

Mr. Harris says he asked the Homeowners 3 times if he could install chicken wire on trench bottom - they declined. No wire installed
 GF 08/20/04
 See Attached

AS BUILT PLANS

