

JURISDICTION
300

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
1901 ALVIN RICKEN DRIVE POCATELLO, ID 83201

Receipt # 7741
FEE PD Y N
PERMIT # 152008

TRAVEL TIME: 30 min
INSPECTION TIME: 15 min

**APPLICATION AND PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE

NAME Scott Wells		PHONE 234-9205	PROPERTY ADDRESS 114 W. Portneuf Rd. Inkom, ID.		
MAILING ADDRESS:		LEGAL DESCRIPTION: LOT SIZE (ACRES) <u>21</u>			
STREET/P.O. BOX 1350 E. Cedar		1/4 SECTION _____ SECTION <u>28</u>		TOWNSHIP <u>75</u> RANGE <u>36E</u>	
CITY Pocatello		LOT # _____ BLOCK # _____		SUBDIVISION _____	
STATE ID		ZIP 83201		PARCEL # <u>R4015026502; R4015026503</u> FROM TAX ASSESSOR'S OFFICE	
SEPTIC TANK SIZE 1250 gal.	EST TYPE 232	EFFECTIVE DISPOSAL AREA 778 SQ.FT.	SOIL TYPE B-2	MAXIMUM DEPTH BELOW GROUND SURFACE 4ft.	# BEDROOMS 5

INSTALLATION MUST BE BY LICENSED SEWER INSTALLER OR HOME/LANDOWNER

EHS SIGNATURE <i>Wendy Broadbent</i>	EMS # 74	APPLICANT SIGNATURE <i>Brandy Wells</i>	DATE 2-22-01
REMARKS			

INSPECTION

THE DISTRICT HEALTH DEPARTMENT SHALL BE NOTIFIED OF INSTALLATION 48 HOURS PRIOR TO BACKFILLING

SEPTIC TANK SIZE 1500 gal	STANDPIPE: () YES <input checked="" type="checkbox"/> NO	MANHOLE DEPTH 18 inches	DEPTH BELOW GROUND SURFACE 4ft.	ROCK UNDER PIPE 27 in ft thunders
EFFECTIVE DISPOSAL AREA 778 sq. ft.	INSTALLATION APPROVED <input checked="" type="checkbox"/> DISAPPROVED _____	INSTALLER Home owner		

EHS SIGNATURE <i>Wendy Broadbent</i>	DATE 3-19-01	CODE (B)	EHS # 74
---	-----------------	-------------	-------------

REMARKS Upper trench is at 4.5 feet, ~~sewer~~, soil will be leveled to 4 ft depth.

WATER SYSTEM

PLANS APPROVED YES <input checked="" type="checkbox"/> NO _____	SAMPLE COLLECTED BY	DATE	STATE LAB INDICATES INTESTINAL BACTERIA WERE _____ WERE NOT _____ FOUND
MIN. DISTANCES PER STANDARDS/REGS. YES <input checked="" type="checkbox"/> NO _____	CHEMICAL PARAMETERS TESTED WITHIN LIMITS YES _____ NO _____		SYSTEM PUBLIC _____ PRIVATE <input checked="" type="checkbox"/>

WELL (SPRING) APPEARS TO MEET CONSTRUCTION STANDARDS AT TIME OF INSPECTION <input checked="" type="checkbox"/> YES () NO	EHS SIGNATURE <i>Wendy Broadbent</i>	EHS # 74
--	---	-------------

REMARKS

