

# WATER AND SEWER PERMIT

Southeastern  
District Health Department

PLANNING & ZONING APPROVAL

Name <b>Town Hall</b>	Phone <b>233-6644</b>	Property Address <b>2207 S. Grant</b>
Address <b>2651 S. Grant.</b>		Legal Description <b>Sec. 1, T7S, R34E</b>
Report To <b>Town Hall.</b>	Funding <input type="checkbox"/> Governmental <input type="checkbox"/> Individual	<input type="checkbox"/> Conventional <input type="checkbox"/> Existing

## SEWAGE SYSTEM

Installation shall comply with all requirements of Health District and/or State of Idaho sewage disposal rules, regulations and standards

Permit No. <b>3008</b>	Permit Fee <b>50.00</b>
SIZE No. Bedrooms: <b>2</b> Septic Tank: <b>750</b> gal. Disposal Area: <b>200</b> sq. ft.	TYPE <input type="checkbox"/> Trench <input type="checkbox"/> Bed <input checked="" type="checkbox"/> Pit <input type="checkbox"/> E.T. <input type="checkbox"/> Sand Filter <input type="checkbox"/> Modified
Dimensions <b>6x6x9 deep</b>	Maximum Depth below Ground Surface <b>12'</b>
PLOT PLAN <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved	By <b>Steven D. VanDunk</b>
Remarks <b>pit excavation to cutbank 3x diameter of pit.</b>	Date <b>4/15/85</b> Permit Fee <b>50.00</b>

## INSPECTION

The District Health Department shall be notified of installation **48 hrs** prior to installation

SEPTIC TANK Size <b>1000</b> gal.	STANDPIPE <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Manhole Depth	DEPTH OF Ground Water	Bedrock	Gravel	Rock Under Pipe
Minimum Distances as per Regulations <input type="checkbox"/> Yes <input type="checkbox"/> No	Approved Aggregate <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Effective Disposal Area <b>315</b> sq. ft.	Installer <b>self</b>			
EXISTING SYSTEM Appears to meet Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	INSTALLATION <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Disapproved	By <b>Fred Huffman</b>		Date <b>5/17/85</b>		
Remarks <b>1) Large 4-6 gravel used 2) Schedule 40 pipe to be run from tank to pipe 3) another row of blocks on top 4) pipe to pit runs uphill (W.L.)</b>						

## WATER SYSTEM

Plans Approved <input type="checkbox"/> Yes <input type="checkbox"/> No	State Laboratory indicates intestinal bacteria <input type="checkbox"/> were <input type="checkbox"/> were not found in water.	Sample Collected By	Date	Permit Fee
Min. Distances as per Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	CHEMICAL TOLERANCES <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Chk'd	System <input type="checkbox"/> Public <input type="checkbox"/> Private	Complies with Health Dist. and/or State of Idaho Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No	
Existing System appears to comply with all requirements of Health Dist. and State of Idaho Drinking Water Standards/Regs <input type="checkbox"/> Yes <input type="checkbox"/> No		INSTALLATION <input type="checkbox"/> Approved <input checked="" type="checkbox"/> Disapproved	By <b>X</b>	Date
Remarks <b>waterline at 48 feet from City water seepage pit and 30 feet from septic tank</b>				

