

JURISDICTION 300

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
465 MEMORIAL DRIVE  
POCATELLO, ID

G.W. 16W

FEE PD  Y  N  
PERMIT # 125233

TRAVEL TIME: 30  
INSPECTION TIME: 45

\*\*APPLICATION AND PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE

NAME Robert Milward		PHONE 234-6595	PROPERTY ADDRESS Johnny Creek Rd. (3535)		
MAILING ADDRESS: P.O. Box 2300		LEGAL DESCRIPTION: LOT SIZE (ACRES) .5		1/4 SECTION NENW SECTION 12 TOWNSHIP 75 RANGE 34E	
STREET/P.O. BOX		LOT #		BLOCK #	
CITY Pocatello		SUBDIVISION		PARCEL # RPPPP126903	
STATE ID		ZIP 83201		FROM TAX ASSESSOR'S OFFICE	
SEPTIC TANK SIZE 1500 gal.	EST TYPE 232	EFFECTIVE DISPOSAL AREA 1333 SQ.FT.	SOIL TYPE C-1	MAXIMUM DEPTH BELOW GROUND SURFACE 4' max	# BEDROOMS 6

INSTALLATION MUST BE BY LICENSED SEWER INSTALLER OR HOME/LANDOWNER

EHS SIGNATURE Angela T. Markham	EHS # 72	APPLICANT SIGNATURE	DATE 12-18-97
------------------------------------	----------	---------------------	------------------

REMARKS Must stay 25' off of southern property line due to neighbor's well.

INSPECTION

THE DISTRICT HEALTH DEPARTMENT SHALL BE NOTIFIED OF INSTALLATION 48 HOURS PRIOR TO BACKFILLING

SEPTIC TANK SIZE 1500 gal.	STANDPIPE: ( ) YES (X) NO	MANHOLE DEPTH 6"	DEPTH BELOW GROUND SURFACE 4'	ROCK UNDER PIPE Int'l
EFFECTIVE DISPOSAL AREA 1333 sq. ft.	INSTALLATION APPROVED X DISAPPROVED	INSTALLER Western Design	INSTALLER # 22815	

EHS SIGNATURE Angela T. Markham	DATE 5/1/98	Code = G	EHS # 72
------------------------------------	-------------	----------	----------

REMARKS Area in back has trees & shed - this is replacement area for drainfield - in event of failure, this area will have to be cleared of trees & structures

PLANS APPROVED YES X NO	SAMPLE COLLECTED BY	DATE	STATE LAB INDICATES INTESTINAL BACTERIA WERE WERE NOT FOUND
-------------------------	---------------------	------	---

MIN. DISTANCES PER STANDARDS/REGS. YES X NO	CHEMICAL PARAMETERS TESTED WITHIN LIMITS YES NO	SYSTEM PUBLIC X PRIVATE
---	---	-------------------------

WELL (SPRING) APPEARS TO MEET CONSTRUCTION STANDARDS AT TIME OF INSPECTION ( ) YES ( ) NO Public	EHS SIGNATURE Angela T. Markham	EHS # 72
--	------------------------------------	----------

REMARKS Will be scraping down 10" to meet 4' max. trench depth.

