

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. _____
Installation for JERRY NORTON (Name) ^{Sold: Michael - Public} at Sec 20 T 7 S R 34 E (Legal description of property) ^{Public 0.000 R 1.3 Box 209 Parkview Rd. 3000}
Date 5-1-75

Address of Installation Intersect of Mink Creek + Parkview Road - By Power Station

No. Living Units 1 Bedrooms 4 People Served 5 Water Supply--Private Public Applicant is: Owner Contractor Other
FHA FARM HOME VA CONV. EXISTING NO.

Septic Tank 1000 gal. Perc. Rate 10 Min./in. Min. Depth to Ground Water _____ ft.
Effluent Disposal: Effective Area Required 660 sq. ft. Soil System: _____ Soil Profile _____
Field Drain Absorption Bed _____ Standard Modified _____ Seepage Pit _____ Dimensions _____

Distance from Disposal Area to:
Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 20 ft. Well 100 ft.
Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved Septic Tank 10 ft.

Remarks: DO NOT BACKFILL WITHOUT INSPECTION
Applicant Jerry Norton Paid _____ Bill _____ No Fee
Address _____ Permit Issued by Tom Hopkins

INSPECTION: Septic Tank Size 1000 gal Standpipe 2' Depth to Manhole _____
Distance from Septic Tank to: Dwelling Foundation _____ ft. Well _____ ft. Nearest Neighbor's Well _____ ft.
Effluent Disposal: Effective Area 750 sq. ft.
Field Drain _____ Absorption Bed _____ Standard Modified _____ Seepage Pit Dimensions 9' deep x 25' x 21'
Pipe Size _____ No. of Lines _____ Length _____ Depth _____

Distance from Disposal Area to:
Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.
Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.
Approved Not Approved _____ Inspected 25 Sept 75 by W.H. Mailover Installed by _____
(Date)

Remarks _____

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

3 lines x 75'-0 long x 3'-0 wide
10'-0 between lines. lines must be level,
changed to seepage pit 18 Sept 1975 to meet
effective area of 660'

INSTALL AS PER

Reference: RULES AND REGULATIONS FOR INDIVIDUAL AND SUBSURFACE SEWAGE DISPOSAL SYSTEMS
Idaho Department of Health, Environmental Improvement Division, August 1971