

JURISDICTION *11/04/05* **SOUTHEASTERN DISTRICT HEALTH DEPARTMENT** 7157  
**300 69** 1901 ALVIN RICKEN DRIVE POCATELLO, ID 83201  
 FEE PD  Y  N  
 PERMIT # **168658**

TRAVEL TIME: 15 /     /      
 INSPECTION TIME: 30 /     /    

Mr. Wood **\*\*APPLICATION AND PERMIT VALID FOR ONE YEAR FROM DATE OF ISSUANCE**

NAME <b>Idaho Rock &amp; Sand LLC</b>	PHONE <b>237-2343</b>	PROPERTY ADDRESS <b>9990 Batiste Road</b>
MAILING ADDRESS <b>3600 mcclaleb dr</b>		LEGAL DESCRIPTION: LOT SIZE (ACRES) <b>4.89</b>
STREET/P.O. BOX	1/4 SECTION <b>NE</b> SECTION <b>17</b> TOWNSHIP <b>6</b> RANGE <b>34</b>	
CITY <b>Pocatello</b>	LOT #	BLOCK #
STATE <b>Idaho</b>	ZIP <b>83201</b>	PARCEL # <b>R3853019103</b>
SEPTIC TANK SIZE <b>1000</b> gal.	EST TYPE <b>235</b>	EFFECTIVE DISPOSAL AREA <b>333</b> SQ. FT.
	SOIL TYPE <b>B2</b>	MAXIMUM DEPTH BELOW GROUND SURFACE <b>3ft</b>
		# BEDROOMS <b>—</b>

INSTALLATION MUST BE BY LICENSED SEWER INSTALLER OR HOME/LANDOWNER

DATE <b>10/12/05</b>	EHS SIGNATURE <i>[Signature]</i>	EHS# <b>69</b>	APPLICANT SIGNATURE <i>[Signature]</i>
-------------------------	-------------------------------------	-------------------	---

REMARKS **Size base on one bedroom home 150gpd; 4 employees.**

**INSPECTION**

**THE DISTRICT HEALTH DEPARTMENT SHALL BE NOTIFIED OF INSTALLATION 48 HOURS PRIOR TO BACKFILLING**

SEPTIC TANK SIZE <b>1000</b> gal.	STANDPIPE: ( ) YES ( <input checked="" type="checkbox"/> ) NO	MANHOLE DEPTH <b>14 inches</b>	DEPTH BELOW GROUND SURFACE <b>4ft</b>	ROCK UNDER PIPE <b>30 QUICK R</b>
EFFECTIVE DISPOSAL AREA <b>656</b> sq. ft.	INSTALLATION APPROVED <input checked="" type="checkbox"/> DISAPPROVED <input type="checkbox"/>	INSTALLER <b>KOGE EXC.</b> INSTALLER # <b>28084</b>		

EHS SIGNATURE <i>[Signature]</i>	DATE <b>11/04/05</b>	CODE <b>G</b>	EHS # <b>69</b>
-------------------------------------	-------------------------	------------------	--------------------

REMARKS **Pump Tank every 3 to 5 years.**

**WATER SYSTEM**

PLANS APPROVED YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	SAMPLE COLLECTED BY	DATE	STATE LAB INDICATES INTESTINAL BACTERIA WERE <input type="checkbox"/> WERE NOT <input type="checkbox"/> FOUND
MIN. DISTANCES PER STANDARDS/REGS. YES <input type="checkbox"/> NO <input type="checkbox"/>	CHEMICAL PARAMETERS TESTED WITHIN LIMITS YES <input type="checkbox"/> NO <input type="checkbox"/>	SYSTEM PUBLIC <input type="checkbox"/> PRIVATE <input checked="" type="checkbox"/>	

WELL (SPRING) APPEARS TO MEET CONSTRUCTION STANDARDS AT TIME OF INSPECTION ( ) YES ( ) NO <b>no well</b>	EHS SIGNATURE	EHS#
--	---------------	------

REMARKS

