

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. _____ Date December 7, 1972

Installation for Cream Top Dairy at 295 East Chubbuck Road
(Name) (Legal description of property)

Address of Installation Chubbuck, Idaho T65 R34E Sec 11

No. Living Units _____ Bedrooms _____ People Served 16 Water Supply--Private _____ Public X Applicant is: Owner X Contractor _____ Other _____

FHA _____ FARM HOME _____ VA _____ CONV. X EXISTING _____ NO. _____

Septic Tank None gal. Perc. Rate 3 Min./in. Min. Depth to Ground Water 15 ft.

Effluent Disposal: Effective Area Required 300 sq. ft. Soil System: Soil Profile Dirt down 8' changing to gravel below

Field Drain _____ Absorption Bed _____ Standard _____ Modified _____ Seepage Pit X Dimensions 10' Diameter
10' deep

Distance from Disposal Area to:
Property Lines: Front 15 ft. Back 478.5 ft. Side 82' ft. Dwelling Foundation 35' ft. Well None ft.

Surface Water NA ft. Nearest Neighbor's Well 150+ ft. Plot Plan Submitted and Approved X Septic Tank None ft.

Remarks: for a distribution outlet

Applicant Ben Williams Paid _____ Bill _____ No Fee

Address Challenge Fine Dairy Foods, Idaho Falls, Idaho Issued by Jaren Tolman

INSPECTION: Septic Tank Size _____ Standpipe _____ Depth to Manhole _____

Distance from Septic Tank to: Dwelling Foundation _____ ft. Well _____ ft. Nearest Neighbor's Well _____ ft.

Effluent Disposal: Effective Area _____ sq. ft.

Field Drain _____ Absorption Bed _____ Standard _____ Modified _____ Seepage Pit _____ Dimensions _____

Pipe Size _____ No. of Lines _____ Length _____ Depth _____

Distance from Disposal Area to:

Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.

Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.

Approved _____ Not Approved _____ Inspected _____ by _____ Installed by _____
(Date)

Remarks _____

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

SEE ATTACHED DRAWING covered w/o inspection