

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

T6S R 34E Sect 5018

Permit No. Richard  
Installation for ~~Stewart~~ Nelson at 237-0694 Date 20 Nov 1972  
(Name) (Legal description of property)  
Address of Installation West Chubbuck, between Philbin + Rio Vista  
No. Living Units 1 Bedrooms 3 People Served \_\_\_\_\_ Water Supply--Private X Public \_\_\_\_\_ Applicant is: Owner \_\_\_\_\_ Contractor X Other \_\_\_\_\_  
FHA X FARM HOME \_\_\_\_\_ VA \_\_\_\_\_ CONV. \_\_\_\_\_ EXISTING \_\_\_\_\_ NO. \_\_\_\_\_

Septic Tank 900 gal. minimum  
Effluent Disposal: Effective Area Required 300 sq. ft. Soil System: Perc. Rate \_\_\_\_\_ Min./in. Min. Depth to Ground Water \_\_\_\_\_ ft.  
Soil Profile 3ft Topsoil Then gravel.  
Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit X Dimensions 8x12' deep.

Distance from Disposal Area to:  
Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 20 ft. Well 100 ft.  
Surface Water \_\_\_\_\_ ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved \_\_\_\_\_ Septic Tank \_\_\_\_\_ ft.

Remarks: \_\_\_\_\_  
Applicant Stewart Nelson Paid \_\_\_\_\_ Bill \_\_\_\_\_ No Fee X  
Address \_\_\_\_\_ Permit Issued by Harry E. Ferguson

INSPECTION: Septic Tank Size 1000 gal. Standpipe 4 foot Depth to Manhole 12 inches / 6 inches  
Distance from Septic Tank to: Dwelling Foundation 20 ft. Well 100 ft. Nearest Neighbor's Well \_\_\_\_\_ ft.  
Effluent Disposal: Effective Area \_\_\_\_\_ sq. ft.  
Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit \_\_\_\_\_ Dimensions \_\_\_\_\_  
Pipe Size \_\_\_\_\_ No. of Lines \_\_\_\_\_ Length \_\_\_\_\_ Depth \_\_\_\_\_

Distance from Disposal Area to:  
Property Lines: Front \_\_\_\_\_ ft. Back \_\_\_\_\_ ft. Side \_\_\_\_\_ ft. Dwelling Foundation \_\_\_\_\_ ft. Well \_\_\_\_\_ ft.  
Surface Water \_\_\_\_\_ ft. Water Service Piping \_\_\_\_\_ ft. Depth to Gravel \_\_\_\_\_ ft. Nearest Neighbor's Well \_\_\_\_\_ ft.  
Approved X Not Approved \_\_\_\_\_ Inspected \_\_\_\_\_ by Ferguson Installed by Christensen  
(Date)  
Remarks House with basement on 1.08 acres

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

Seepage Pit Size:  
8ft. deep below inlet  
12 ft diameter

Seepage pit must be minimum of 100 ft from any wells, including neighbors

existing home here

