

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. \_\_\_\_\_ at \_\_\_\_\_ Page 6-4-73  
 Installation for Bruce Taylor (Name) at Pocatello Creek Road (Legal description of property)  
 Address of Installation Arnor Anderson property T6S, R34, S13  
 No. Living Units 1 Bedrooms 3 People Served 2 Water Supply--Private  Public \_\_\_\_\_ Applicant is: Owner  Contractor \_\_\_\_\_ Other \_\_\_\_\_  
 FHA \_\_\_\_\_ FARM HOME \_\_\_\_\_ VA \_\_\_\_\_ CONV.  EXISTING \_\_\_\_\_ NO. \_\_\_\_\_

Septic Tank \_\_\_\_\_ gal. Perc. Rate 3 Min./in. Min. Depth to Ground Water \_\_\_\_\_ ft.  
 Effluent Disposal: Effective Area Required 300 sq. ft. Soil System: Soil Profile silt loam & shale below  
 Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit  Dimensions 10'x10' delay

Distance from Disposal Area to:  
 Property Lines: Front \_\_\_\_\_ ft. Back \_\_\_\_\_ ft. Side \_\_\_\_\_ ft. Dwelling Foundation \_\_\_\_\_ ft. Well 120 ft.

Surface Water none ft. Nearest Neighbor's Well 900 ft. Plot Plan Submitted and Approved  Septic Tank \_\_\_\_\_ ft.  
 Remarks: 5 pages (no permit will be issued for further subdividing, approved for the well & water supply)  
 Applicant Bruce Taylor Paid \_\_\_\_\_ Bill \_\_\_\_\_ No Fee   
 Address 400 Stewart, Pocatello Permit Issued by Paul Cleaver

INSPECTION: Septic Tank Size 1000 Standpipe no Depth to Manhole 12"

Distance from Septic Tank to: Dwelling Foundation 5 ft. Well Not in ft. Nearest Neighbor's Well 100 ft.

Effluent Disposal: Effective Area 300 sq. ft.  
 Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard  Modified \_\_\_\_\_ Seepage Pit  Dimensions 10'x10'  
 Pipe Size 4" No. of Lines \_\_\_\_\_ Length \_\_\_\_\_ Depth \_\_\_\_\_

Distance from Disposal Area to:  
 Property Lines: Front 710 ft. Back 710 ft. Side 710 ft. Dwelling Foundation 20 ft. Well Not in ft.

Surface Water 7300 ft. Water Service Piping \_\_\_\_\_ ft. Depth to Gravel none ft. Nearest Neighbor's Well 7000 ft.  
 Approved  Not Approved \_\_\_\_\_ Inspected 6-25-73 by John Tolman Installed by Jess Coffin  
 Remarks no shale hit

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

*See attached sketch*

*construct/bulletin 6*