

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. _____ Date 24 Jun 1974
 Installation for DONALD TALBOT at T 6 S R 34 E S 5
 (Name) (Legal description of property)
 Address of Installation CORNER OF RIO VISTA + Chubbuck
 No. Living Units 1 Bedrooms 3 People Served 4 Water Supply--Private Public _____ Applicant is: Owner Contractor _____ Other _____
 FHA _____ FARM HOME _____ VA _____ CONV. _____ EXISTING _____ NO. _____
 Septic Tank 1000 gal. 300 Perc. Rate 0 Min./in. Min. Depth to Ground Water _____ ft.
 Effluent Disposal: Effective Area Required 300 sq. ft. Soil System: Soil Profile GRAVEL
 Field Drain Absorption Bed _____ Standard Modified _____ Seepage Pit _____ Dimensions _____
 Distance from Disposal Area to:
 Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 15 ft. Well 100 ft.
 Surface Water _____ ft. Nearest Neighbor's Well _____ ft. Plot Plan Submitted and Approved _____ Septic Tank _____ ft.
 Remarks: DO NOT BACKSILL WITHOUT INSPECTION
 Applicant Donald E Talbot Paid _____ Bill _____ No Fee
 Address _____ Permit Issued by Tom Hopkins
 INSPECTION: Septic Tank Size 1000 Standpipe no Depth to Manhole 12"
 Distance from Septic Tank to: Dwelling Foundation _____ ft. Well _____ ft. Nearest Neighbor's Well _____ ft.
 Effluent Disposal: Effective Area _____ sq. ft.
 Field Drain _____ Absorption Bed _____ Standard _____ Modified _____ Seepage Pit Dimensions _____
 Pipe Size 4 No. of Lines _____ Length _____ Depth _____
 Distance from Disposal Area to:
 Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.
 Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.
 Approved Not Approved _____ Inspected 8-16-74 by Tom Hopkins Installed by Gary Porter
 (Date)

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

2- 50'-0 lines x 3'-0" wide with interconnect
 This system was changed to a seepage pit, I approved the change. APPROVAL OF SYSTEM IS PENDING ON OBTAINING legal description OF PROPERTY showing ownership of minimum of 1 Acre- 8-8-74 TH