

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Permit No. _____ Date 6 June 1975
 Installation for Gary J. Ruchti at NE 1/4 NW 1/4 Sec 33 T6 S R34E
(Name) (Legal description of property)
 Address of Installation 1 1/2 miles up trail ~~to~~ creek then left 1/2 mi.
 No. Living Units 1 Bedrooms 4 People Served 5 Water Supply--Private X Public _____
 Applicant is: Owner X Contractor _____ Other _____
 FHA _____ FARM HOME _____ VA _____ CONV. _____ EXISTING _____ NO. _____

Septic Tank 1000 gal. Perc. Rate 7 Min./in. Min. Depth to Ground Water _____ ft.
 Effluent Disposal: Effective Area Required 600 sq. ft. Soil System: _____ Soil Profile _____
 Field Drain _____ Absorption Bed X Standard X Modified _____ Seepage Pit _____ Dimensions _____

Distance from Disposal Area to:
 Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 20 ft. Well 100 ft.
 Surface Water _____ ft. Nearest Neighbor's Well _____ ft. Plot Plan Submitted and Approved _____ Septic Tank 5 ft.
 Remarks: Have system inspected and approved before backfilling
 Applicant Gary J. Ruchti Paid _____ Bill _____ No Fee _____
 Address _____ Permit Issued by William H. Maibauer

INSPECTION: Septic Tank Size _____ Standpipe _____ Depth to Manhole _____
 Distance from Septic Tank to: Dwelling Foundation _____ ft. Well _____ ft. Nearest Neighbor's Well _____ ft.
 Effluent Disposal: Effective Area _____ sq. ft.
 Field Drain _____ Absorption Bed _____ Standard _____ Modified _____ Seepage Pit _____ Dimensions _____
 Pipe Size _____ No. of Lines _____ Length _____ Depth _____

Distance from Disposal Area to:
 Property Lines: Front _____ ft. Back _____ ft. Side _____ ft. Dwelling Foundation _____ ft. Well _____ ft.
 Surface Water _____ ft. Water Service Piping _____ ft. Depth to Gravel _____ ft. Nearest Neighbor's Well _____ ft.
 Approved X Not Approved _____ Inspected 12 Aug 75 by H. Fugesaw Installed by John Long
(Date) (Licensed)
 Remarks _____

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

