

SOUTHEASTERN DISTRICT HEALTH DEPARTMENT  
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

220

Permit No. \_\_\_\_\_ Date 8/23/76  
Installation for BILL SANT- PHOTO ROOPER at SEC 21 T6S R 34  
(Name) (Legal description of property)

Address of Installation KEAT ROAD

No. Living Units 1 Bedrooms - People Served - Water Supply--Private  Public   
Applicant is: Owner  Contractor  Other

FHA  FARM HOME  VA  CONV.  EXISTING  NO.

Septic Tank 1000 gal. Perc. Rate \_\_\_\_\_ Min./in. Min. Depth to Ground Water \_\_\_\_\_ ft.  
Effluent Disposal: Effective Area Required 300 sq. ft. Soil System: Soil Profile \_\_\_\_\_  
Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard \_\_\_\_\_ Modified \_\_\_\_\_ Seepage Pit  Dimensions \_\_\_\_\_

Distance from Disposal Area to:  
Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 720 ft. Well 100 ft.  
Surface Water 150 ft. Nearest Neighbor's Well 100 ft. Plot Plan Submitted and Approved \_\_\_\_\_ Septic Tank \_\_\_\_\_ ft.

Remarks: DO NOT BACKFILL WITHOUT INSPECTION.

Applicant X William X Sant Paid \_\_\_\_\_ Bill \_\_\_\_\_ No Fee

Address \_\_\_\_\_ Permit Issued by TOM HOPKINS

INSPECTION: Septic Tank Size 1000 Standpipe None Depth to Manhole 8

Distance from Septic Tank to: Dwelling Foundation 8 ft. Well >100 ft. Nearest Neighbor's Well >100 ft.

Effluent Disposal: Effective Area \_\_\_\_\_ sq. ft.

Field Drain \_\_\_\_\_ Absorption Bed \_\_\_\_\_ Standard  Modified \_\_\_\_\_ Seepage Pit  Dimensions 9' x 14 ft wide

Pipe Size 4 No. of Lines 1 Length \_\_\_\_\_ Depth \_\_\_\_\_

Distance from Disposal Area to:  
Property Lines: Front >10 ft. Back >10 ft. Side >10 ft. Dwelling Foundation 30 ft. Well >100 ft.  
Surface Water >150 ft. Water Service Piping >50 ft. Depth to Gravel >10 ft. Nearest Neighbor's Well >100 ft.

Approved  Not Approved \_\_\_\_\_ Inspected 30-177 by JACK E. BOWMAN Installed by SELF  
(Date)

Remarks \_\_\_\_\_

Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) --

SEEPAGE PIT EXAMPLE!  
12'-0 DIA X 8'-0 COLE BELOW INLET PIPE

