
SOUTHEASTERN DISTRICT HEALTH DEPARTMENT INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

| Permit No. Date fanciary 28, 197 |
|--|
| Installation for MIKE HEBERLEIN at Me Sw Sec 1 7) S R 34/E (Name) (Legal description of property) |
| Address of Installation GRANT + RANNOCK HIMAY |
| No. Living Units Bedrooms 3 People Served Water SupplyPrivate Applicant is: Contractor Other |
| FHA FARM HOME VA CONV EXISTING NO |
| Septic Tank 1000 gal. Perc. Rate 15 Min./in. Min. Depth to Ground Water ft. |
| Effluent Disposal: Effective Area Required _S86 sq. ft. Soil System: Soil Profile |
| Field Drain Absorption Bed Standard Modified Seepage Pit Dimensions X3 O |
| Distance from Disposal Area to: |
| Property Lines: Front 10 ft. Back 10 ft. Side 10 ft. Dwelling Foundation 20 ft. Well ft. |
| Surface Water ft. Nearcst Neighbor's Well 150 ft. Plot Plan Submitted and Approved $\sqrt{}$ Septic Tank $\sqrt{0}$ ft. |
| Remarks: Hoye system inspected before backfilling |
| Applicant Paid Bill No Fee |
| Address P.O. Box 4135 Permit Issued by Jed Huffman |
| |
| INSPECTION: Septic Tank Size OOO Standpipe Depth to Manhole / Depth to |
| Effluent Disposal: Effective Area 560 sq. ft. |
| |
| Field Drain Absorption Bed Standard Modified Seepage Pit Dimensions // X / Z Pipe Size No. of Lines Length Depth |
| Distance from Disposal Area to: |
| Property Lines: Front ft. Back ft. Side ft. Dwelling Foundation ft. Well ft. |
| Surface Water ft. Water Service Piping ft. Depth to Gravel ft. Nearest Neighbor's Well ft. |
| 1 1 |
| Approved Not Approved Inspected 5-25-77 by Toyn Hopkins Installed by Atha Long (Date) |
| Remarks ViA Shone - Licensed installers |
| |
| Applicant's sketch of house, proposed sewage layout and all adjacent wells (dimension between all components) |
| * This permit issued on the basis of pere test done at the |
| Johnah Witness Church - installed 1976 |
| 10-0 Core |
| 70-0 60.6 |
| 5'-0 |
| |

320 240 560

eres which may be subject to flooding? (For essente,