SOUTHEASTERN DISTRICT HEALTH DEPARTMENT INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Fermit No.	Date
Installation for MIKE JAKELARIS	at NW /4 NE /4 Sec 33 T 65 234 E
Address of Installation TRAIL CREEK- SE	
	4 Water SupplyPrivate Owner Applicant is: Contractor Other
FHA FARM HOME VA CONV	EXISTING NO.
Septic Tank /000 gal.	Perc. Rate 5 Min./in. Min. Depth to Ground Water ft.
Effluent Disposal: Effective Area Required 600 sq. ft	Soil System: Soil Profile
Field Drain Absorption Bed Standard	Modified Seepage Pit Dimensions
Distance from Disposal Area to:	
Property Lines: Front ft. Back ft.	Side 16 ft. Dwelling Foundation 15 ft. Well 100 ft.
Surface Water 50 ft. Nearcst Neighbor's Well 10	of ft. Plot Plan Submitted and Approved Septic Tank 10 ft.
Remarks: DO NOT BACKSILL WITHOUT	Inspection - 3 DAYS Notice
Applicant & Much Salilari	Paid No Fee
,	Permit Issued by 10M Hopkins
INSPECTION: Septic Tank Size 1000 Standp	Depth to Manhole 10
Distance from Septic Tank to: Dwelling Foundation	ft. Well 100 ft. Nearest Neighbor's Well ft.
Effluent Disposal: Effective Area 6000 sq. ft.	
Field Drain Absorption Bed Standard	Modified Seepage Pit Dimensions
Field DrainAbsorption BedStandard Pipe Size# No. of Lines Length	25 Depth 18 -36"
Distance from Disposal Area to:	
Property Lines: Front ft. Back ft.	Sideft. Dwelling Foundationft. Wellft.
Surface Water ft. Water Service Piping	ft. Depth to Gravel ft. Nearest Neighbor's Well ft.
Approved Not Approved Inspected $\frac{9-9-76}{\text{(Date)}}$ by	John LOPKins Installed by Enoch Jour
Remarks	
Applicant's sketch of house, proposed sewage layout and all ad	jacent wells (dimension between all components)
PRAIN FIELD EXAMPle: 2-100-0	lines x 3'-0 wice. min. 6'-0 undisturbe
EARTH B	etween Lines Lines
Connect	between Lines, ALL Lines To Be inter
	A 1
* change to a seepag	e bed 20 x 30 = 600 y ft
420 30	, \fi
O kines	
	20